

PORTABLE APPLIANCE TEST CERTIFICATE

Site: Musicology

Reference: M17

Appliance Identity Description	Location Serial Number	Test Date Next Test Date	Visual Check	Earth Bond Current Resistance	Insulation Resistance	Flash	Load kVA A	Leakage	Substitute Leakage	Touch Leakage	Continuity	Comments	Result
000000001 sensory light	studio	24/03/2017 24/03/2018	Pass	200.00 mA 0.16 OHM Pass	Skip	Skip	Skip	Skip	0.03 mA Pass	Skip	Skip		Pass
000000002 sensory light	studio	24/03/2017 24/03/2018	Pass	200.00 mA 0.18 OHM Pass	Skip	Skip	Skip	Skip	0.03 mA Pass	Skip	Skip		Pass
000000003 sensory light	studio	24/03/2017 24/03/2018	Pass	200.00 mA 0.05 OHM Pass	Skip	Skip	Skip	Skip	0.51 mA Pass	Skip	Skip		Pass
000000004 sensory light	studio	24/03/2017 24/03/2018	Pass	200.00 mA 0.12 OHM Pass	Skip	Skip	Skip	Skip	0.04 mA Pass	Skip	Skip		Pass
000000005 powered speaker	studio	24/03/2017 24/03/2018	Pass	200.00 mA 0.09 OHM Pass	Skip	Skip	Skip	Skip	0.52 mA Pass	Skip	Skip		Pass
000000006 powered speaker	studio	24/03/2017 24/03/2018	Pass	200.00 mA 0.45 OHM Pass	Skip	Skip	Skip	Skip	0.55 mA Pass	Skip	Skip		Pass
000000007 laptop	studio	24/03/2017 24/03/2018	Pass	Skip	50.00 MEG Pass	Skip	Skip	Skip	Skip	0.00 mA Pass	Pass		Pass
000000008 laser light	studio	24/03/2017 24/03/2018	Pass	200.00 mA 0.04 OHM Pass	Skip	Skip	Skip	Skip	0.63 mA Pass	Skip	Skip		Pass
000000009 smoke machine	studio	24/03/2017 24/03/2018	Pass	200.00 mA 0.29 OHM Pass	Skip	Skip	Skip	Skip	0.20 mA Pass	Skip	Skip		Pass
000000010 prismo 60	studio	24/03/2017 24/03/2018	Pass	200.00 mA 0.07 OHM Pass	Skip	Skip	Skip	Skip	0.24 mA Pass	Skip	Skip		Pass
000000011 prismo 60	studio	24/03/2017 24/03/2018	Pass	200.00 mA 0.07 OHM Pass	Skip	Skip	Skip	Skip	0.07 mA Pass	Skip	Skip		Pass
000000012 ultra bar 6	studio	24/03/2017 24/03/2018	Pass	200.00 mA 0.02 OHM Pass	Skip	Skip	Skip	Skip	0.28 mA Pass	Skip	Skip		Pass
000000013 ultra bar 6	studio	24/03/2017 24/03/2018	Pass	200.00 mA 0.07 OHM Pass	Skip	Skip	Skip	Skip	0.28 mA Pass	Skip	Skip		Pass
000000014 ultra bar 12	studio	24/03/2017 24/03/2018	Pass	200.00 mA 0.00 OHM Pass	Skip	Skip	Skip	Skip	0.24 mA Pass	Skip	Skip		Pass
000000015 sd 300	studio	24/03/2017 24/03/2018	Pass	200.00 mA 0.48 OHM Pass	Skip	Skip	Skip	Skip	0.07 mA Pass	Skip	Skip		Pass

Signature: _____

Date: _____

PORTABLE APPLIANCE TEST CERTIFICATE

Site: Musicology

Reference: M17

Appliance Identity Description	Location Serial Number	Test Date Next Test Date	Visual Check	Earth Bond Current Resistance	Insulation Resistance	Flash	Load kVA A	Leakage	Substitute Leakage	Touch Leakage	Continuity	Comments	Result
000000016 chavet barrel	studio	24/03/2017 24/03/2018	Pass	200.00 mA 0.00 OHM Pass	Skip	Skip	Skip	Skip	0.13 mA Pass	Skip	Skip		Pass
000000017 chavet barrel	studio	24/03/2017 24/03/2018	Pass	200.00 mA 0.04 OHM Pass	Skip	Skip	Skip	Skip	0.13 mA Pass	Skip	Skip		Pass
000000018 mixer	studio	24/03/2017 24/03/2018	Pass	200.00 mA 0.27 OHM Pass	Skip	Skip	Skip	Skip	0.46 mA Pass	Skip	Skip		Pass
000000019 strobe master	studio	24/03/2017 24/03/2018	Pass	Skip	>299.90 MEG Pass	Skip	Skip	Skip	Skip	0.00 mA Pass	Pass		Pass
000000020 strobe	studio	24/03/2017 24/03/2018	Pass	200.00 mA 0.50 OHM Pass	Skip	Skip	Skip	Skip	0.05 mA Pass	Skip	Skip		Pass
000000021 hercules controller	studio	24/03/2017 24/03/2018	Pass	Skip	>299.90 MEG Pass	Skip	Skip	Skip	Skip	0.00 mA Pass	Pass		Pass
000000022 extension lead	studio	24/03/2017 24/03/2018	Pass	10.00 A 0.28 OHM Pass	>299.90 MEG Pass	Skip	Skip	Skip	Skip	Skip	Pass		Pass
000000023 extension lead	studio	24/03/2017 24/03/2018	Pass	10.00 A 0.27 OHM Pass	>299.90 MEG Pass	Skip	Skip	Skip	Skip	Skip	Pass		Pass
000000024 switch	studio	24/03/2017 24/03/2018	Pass	200.00 mA 0.65 OHM Pass	Skip	Skip	Skip	Skip	0.06 mA Pass	Skip	Skip		Pass
000000025 extension lead	studio	24/03/2017 24/03/2018	Pass	10.00 A 0.38 OHM Pass	>299.90 MEG Pass	Skip	Skip	Skip	Skip	Skip	Pass		Pass
000000026 extension lead	studio	24/03/2017 24/03/2018	Pass	10.00 A 0.19 OHM Pass	>299.90 MEG Pass	Skip	Skip	Skip	Skip	Skip	Pass		Pass
000000027 extension lead	studio	24/03/2017 24/03/2018	Pass	Skip	Skip	Skip	Skip	Skip	Skip	Skip	Skip	surge protected	Pass

Signature: _____

Date: _____